DIESEL ENGINES

G03GI-UF08

UL file EX28019 / FM certificate PI3063920
Held by Greaves Cotton Ltd

Greaves / 3G11

75–80
Rated output (hp)

1,470–2,350
Rated speed (rpm)

5
Operating points

Model and construction

Application	Stationary fire pump drive
Cooling	Heat exchanger
Engine arrangement	3 cylinders in line
Aspiration	Turbocharged
Starting system	12 V DC
Family bore × stroke	108 × 133 mm

Rated operating points

rpm	hp
1,470	75
1,760	80
1,960	75
2,100	75
2,350	76

Technical references

3G11 engine family specifications

Manufacturer fire engine range

Approval and selection

UL Listed (file EX28019) at the ratings shown

Greaves Cotton Ltd holds UL file EX28019 for this engine model; the documented shaft duties apply to this selection. FM certificate PI3063920. Confirm the supplied engine nameplate, build and site conditions in the project submittal.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.