DIESEL ENGINES

# G04GI-UF12

UL file EX28019 / FM certificate PI3063920
Held by Greaves Cotton Ltd

Greaves / 4G11

**105–125**
Rated output (hp)

**1,470–2,350**
Rated speed (rpm)

**5**
Operating points

## Model and construction

| | |
|---|---|
| Application | Stationary fire pump drive |
| Cooling | Heat exchanger |
| Engine arrangement | 4 cylinders in line |
| Aspiration | Turbocharged |
| Starting system | 12 V DC |
| Family bore × stroke | 108 × 133 mm |

## Rated operating points

| rpm | hp |
|---|---|
| 1,470 | 105 |
| 1,760 | 120 |
| 1,960 | 115 |
| 2,100 | 125 |
| 2,350 | 125 |

### Technical references

4G11 engine family specifications

Manufacturer fire engine range

## Approval and selection

UL Listed (file EX28019) at the ratings shown

Greaves Cotton Ltd holds UL file EX28019 for this engine model; the documented shaft duties apply to this selection. FM certificate PI3063920. Confirm the supplied engine nameplate, build and site conditions in the project submittal.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.