DIESEL ENGINES

DV12TA

Kirloskar Oil Engines / DV / Build DV8.1048

750
Rated output (hp)

1,500
Rated speed (rpm)

1
Operating point

Model and construction

Application	Stationary fire pump drive
Cooling	Radiator
Rating basis	Continuous engine output at the stated speed
Engine arrangement	V12
Displacement	23.88 L
Aspiration	Turbocharged and aftercooled
Selection note	Earlier radiator build reference. The September schedule identifies the 750 hp radiator build as DV2.1048. Confirm the code on the engine documentation.

Rated operating points

rpm	hp
1,500	750

Technical references

Manufacturer fire engine range

Approval and selection

For fire pump projects whose specification and approving authority permit a non-listed diesel driver.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.