DIESEL ENGINES

KFP4R-UF15

UL file EX15277 / FM approval record on request
Held by Kirloskar Oil Engines Ltd

Kirloskar Oil Engines / KFP4R / Build 4H.2593

111
Rated output (hp)

2,100
Rated speed (rpm)

1
Operating point

Model and construction

Application	Stationary emergency fire pump drive
Cooling	Heat exchanger
Rating basis	Stationary emergency fire pump service
Engine arrangement	4 cylinders in line
Displacement	4.16 L
Aspiration	Turbocharged and aftercooled

Rated operating points

rpm	hp
2,100	111

Technical references

Manufacturer fire engine range

Approval and selection

UL Listed (file EX15277) at the ratings shown

Kirloskar Oil Engines Ltd holds UL file EX15277 for this engine model; the documented shaft duties apply to this selection. FM approval record on request. Confirm the supplied engine nameplate, build and site conditions in the project submittal.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.