DIESEL ENGINES

KFP6R-UF25

UL file EX15277 / FM approval record on request
Held by Kirloskar Oil Engines Ltd

Kirloskar Oil Engines / KFP6R / Build 6H.2618

169
Rated output (hp)

1,760
Rated speed (rpm)

1
Operating point

Model and construction

Application	Stationary emergency fire pump drive
Cooling	Heat exchanger
Rating basis	Stationary emergency fire pump service
Engine arrangement	6 cylinders in line
Displacement	6.48 L
Aspiration	Turbocharged and aftercooled

Rated operating points

rpm	hp
1,760	169

Technical references

Manufacturer fire engine range

Approval and selection

UL Listed (file EX15277) at the ratings shown

Kirloskar Oil Engines Ltd holds UL file EX15277 for this engine model; the documented shaft duties apply to this selection. FM approval record on request. Confirm the supplied engine nameplate, build and site conditions in the project submittal.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.