DIESEL ENGINES

# KFP6R-UF25

UL file EX15277 / FM approval record on request
Held by Kirloskar Oil Engines Ltd

Kirloskar Oil Engines / KFP6R / Build 6H.2622

**225**
Rated output (hp)

**2,600**
Rated speed (rpm)

**1**
Operating point

## Model and construction

| | |
|---|---|
| Application | Stationary emergency fire pump drive |
| Cooling | Heat exchanger |
| Rating basis | Stationary emergency fire pump service |
| Engine arrangement | 6 cylinders in line |
| Displacement | 6.48 L |
| Aspiration | Turbocharged and aftercooled |

## Rated operating points

| rpm | hp |
|---|---|
| 2,600 | 225 |

### Technical references

Manufacturer fire engine range

## Approval and selection

UL Listed (file EX15277) at the ratings shown

Kirloskar Oil Engines Ltd holds UL file EX15277 for this engine model; the documented shaft duties apply to this selection. FM approval record on request. Confirm the supplied engine nameplate, build and site conditions in the project submittal.

For duty confirmation, provide the model and build, required shaft power and speed, site altitude and maximum ambient temperature.